



STONEY POINT  
WATER TREATMENT PLANT  
  
DRINKING WATER SURVEILLANCE  
PROGRAM

ANNUAL REPORT - 1986

MAY, 1987

TD  
380  
.S76  
1987



Ontario

Ministry  
of the  
Environment

J. Bishop, Director  
Water Resources Branch

Copyright Provisions and Restrictions on Copying:

This Ontario Ministry of the Environment work is protected by Crown copyright (unless otherwise indicated), which is held by the Queen's Printer for Ontario. It may be reproduced for non-commercial purposes if credit is given and Crown copyright is acknowledged.

It may not be reproduced, in all or in part, part, for any commercial purpose except under a licence from the Queen's Printer for Ontario.

For information on reproducing Government of Ontario works, please contact Service Ontario Publications at [copyright@ontario.ca](mailto:copyright@ontario.ca)

TD  
430  
S76  
1987

**STONEY POINT WATER TREATMENT PLANT**

**DRINKING WATER SURVEILLANCE  
PROGRAM**

**ANNUAL REPORT - 1986**

ISBN 0-7729-2566-6

MAY, 1987

**ONTARIO MINISTRY OF THE ENVIRONMENT**

## Southwestern Region



## STONEY POINT WATER TREATMENT PLANT

Location: 6011 St. Clair Road West  
P.O. Box 70  
Stoney Point, Ontario  
NOR 1N0  
(519-798-3313)

Source: Lake St. Clair

Design Capacity: 4.45 1000 M3/day  
Operation: Municipal  
Plant Superintendent: G. Scroggins

Ministry Region: Southwestern Region  
Windsor District Office  
250 Windsor Avenue, 6th Floor  
Windsor, Ontario  
N9A 6V9  
(519-254-2546)

Municipalities Served: Tilbury North (3,155)  
Tilbury West (326)

Treatment Type: Physical and chemical treatment consisting of  
coagulation, flocculation sedimentation and  
filtration (conventional) and disinfection.

Chemicals Used: Coagulation - alum liquid  
Post chlorination - chlorine

## STONEY POINT WATER TREATMENT PLANT

### EXECUTIVE SUMMARY DRINKING WATER SURVEILLANCE PROGRAM, 1986

The Stoney Point Water Treatment Plant was sampled 10 times in 1986; results are given for raw and treated samples.

The parameters analyzed fall into several categories: physical parameters and general chemistry, bacterial parameters, metals, and organic substances including volatile and chloroaromatic substances and pesticides.

The discussion of results focuses on health-related parameters found in treated water:

#### (a) Organic Substances

Analysis was carried out for approximately 110 organic compounds. The only volatile compounds found, trihalomethanes (THMs) were always present in treated waters; the highest level recorded for total THMs was 75 ug/L.

None of the pesticides analyzed for was found.

No chlorophenolic compounds were analyzed for.

Three chloroaromatic compounds were found in treated water. Hexachloroethane was found once at 12 ng/L as was 1,2,3,5-tetrachlorobenzene at 31 ng/L, while 2,3,6-trichlorotoluene was found twice at 50 ng/L and 26 ng/L.

#### (b) Other Parameters

The aesthetic ODWO\* for organic nitrogen was exceeded in three treated water samples. Of the other physical, general chemistry and microbiological parameters and metals analyzed, for which there are health-related ODWO, none exceeded the objectives, in treated water.

The results of these analyses are consistent with those obtained in other areas of the Great Lakes.

The treated water from the supply did not exceed any known health-related guidelines for organic substances applicable to drinking water.

---

\* The Ontario Drinking Water Objectives, revised 1983.

**STONEY POINT WATER TREATMENT PLANT**  
**SUMMARY TABLE OF RESULTS**  
**DRINKING WATER SURVEILLANCE PROGRAM, 1986**

The Stoney Point Water Treatment Plant was sampled 10 times in 1986.

| PARAMETER CATEGORY  | TYPE OF SAMPLE |          |
|---|----------------|----------|
|   | RAW            | TREATED* |
| 1. GENERAL CHEMISTRY - includes <u>anions</u> such as sulphate, <u>field analyses</u> such as chlorine residual and <u>physical parameters</u> such as colour.                        |                |          |
| Total number of parameters in category: 21  |                |          |
| - Total number of analyses completed  | 180            | 180      |
| - Total number of positive results  | 178            | 133      |
| - <b>Number of times guidelines exceeded</b>  | <b>N/A</b>     | <b>3</b> |
| Guidelines exceeded - aesthetic ODWO** for organic nitrogen (3)   |                |          |
| 2. METALS - includes metals such as copper and lead.  |                |          |
| Total number of parameters in category: 24  |                |          |
| - Total number of analyses completed  | 191            | 210      |
| - Total number of positive results  | 95             | 96       |
| - <b>Number of times guidelines exceeded</b>  | <b>N/A</b>     | <b>0</b> |
| 3. BACTERIOLOGY - includes bacteria such as coliforms.  |                |          |
| Total number of parameters in category: 5   |                |          |
| - Total number of analyses completed  | 34             | 39       |
| - Total number of positive results  | 25             | 4        |
| - <b>Number of times guidelines exceeded</b>  | <b>N/A</b>     | <b>0</b> |
| 4. VOLATILES - includes compounds such as benzene and toluene; also included in this category are trihalomethanes (5 parameters), acknowledged to be produced during water treatment. |                |          |
| Total number of parameters in category: 29  |                |          |
| - Total number of analyses completed  | 277            | 249      |
| - Total number of positive results  | 0              | 36       |
| - <b>Number of times guidelines exceeded</b>  | <b>N/A</b>     | <b>0</b> |
| 5. PESTICIDES -   |                |          |
| Total number of parameters possible in category: 65   |                |          |
| - Total number of analyses completed  | 246            | 222      |
| - Total number of positive results  | 0              | 0        |
| - <b>Number of times guidelines exceeded</b>  | <b>N/A</b>     | <b>0</b> |
| 6. CHLOROAROMATICS AND CHLOROPHENOLS - includes a range of chlorinated organic compounds.   |                |          |
| Total number of parameters possible in category: 19   |                |          |
| - Total number of analyses completed  | 130            | 114      |
| - Total number of positive results  | 0              | 4        |
| - <b>Number of times guidelines exceeded</b>  | <b>N/A</b>     | <b>0</b> |

\* Total number of analyses completed will not always equal the number of parameters analyzed for multiplied by number of times the supply was sampled, because of accidents during shipping or analyses or analytical difficulties.

\*\* Ontario Drinking Water Objective.

## DRINKING WATER SURVEILLANCE PROGRAM

The Drinking Water Surveillance Program (DWSP) for Ontario is a computerized drinking water information system. The objectives of this program are to provide:

- immediate, reliable, current information on drinking water quality,
- a flagging mechanism for 'Objective' exceedence,
- a definition of contaminant levels and trends,
- a comprehensive background for remedial action,
- a framework for assessment of new contaminants,
- an indication of treatment efficiency of plant processes.

### Program

The DWSP began in April 1986 and is designed to eventually include all municipal water supplies in Ontario. Water supply locations have been prioritized for surveillance, based primarily on such criteria as population density, probability of contamination and geographical location.

Once the data base becomes established, an assessment of monitoring requirements for the future will be made; monitoring will be continued at the initial locations at an appropriate level and further locations will be phased on to the program as resources permit. It is



estimated that after 4 years of operation, the program will be monitoring 90 locations.

A major goal of the program is to collect valid water quality data, in context with plant operation characteristics in the plant at the time of sampling.

Assessments are carried out at all locations prior to sampling in order to acquire full plant process and distribution system details, and to designate (and retrofit if necessary) all sampling systems and locations.

Samples are taken of the raw (ambient water quality) and treated water at the treatment plants, and also in the distribution systems. In order to determine possible effects of distribution on water quality, both standing and flowing water in old and new sections of the distribution system are sampled. Sampling is carried out by Ministry of the Environment (MOE) Regional staff and/or Municipal personnel who have been trained in the applicable procedures. Comprehensive sampling kits and documented sampling procedures are made available to samplers. This ensures that samples are taken and shipped according to standard protocols and that field testing will supply reliable data. All analyses are carried out using approved documented procedures.

#### Data Reporting Mechanism

Final analytical results are usually received by the DWSP reporting system within 6 weeks of the time of sampling. At this time, printouts of the completed analyses are sent to the MOE District Officer and the appropriate MOE regional office, and are also retained by the DWSP co-ordinator. The DWSP is able to monitor analysis results and assess trends. Should the level of

a contaminant exceed a health-related Ontario Drinking Water Objective, action is required as outlined in the publication, Ontario Drinking Water Objectives.\* The DWSP issues an "Action Alert" which notifies appropriate MOE and health authorities, and supplies a history of the occurrence of the contaminant in the water supply system concerned.

#### Parameters Analyzed

About one hundred and forty (140) different parameters are routinely measured on DWSP covering microbiological, organic and inorganic substances of concern, as well as process parameters.

Parameters included in the program are based on the following criteria:

- probability that the substance has the potential to cause problems (health-related or aesthetic);
- probability of occurrence in ambient water;
- availability of routine analytical and sampling methods for monitoring and control purposes;
- feasibility of control.

The range of parameters includes those having Ontario Drinking Water Objectives (ODWO), World Health Organization Drinking Water Guideline values, or other

---

\* Ontario Drinking Water Objectives, revised 1983, published by the Ontario Ministry of the Environment.

jurisdiction's drinking water objectives (e.g. State of California) as well as compounds of concern to other agencies such as the International Joint Commission, and U.S. Environmental Protection Agency.

The parameters monitored routinely during 1986 are shown in Table 1; this table also includes available guidelines which are appropriate for drinking water, and the analytical detection limit (the lowest concentration that can be detected by laboratory analysis) for each parameter.

Analyses for additional pesticides may be included on certain sampling dates; such additional pesticides are selected from the list shown in Table 1A. These analyses may be done on a seasonal basis, in response to an identified concern or because of a potential for occurrence in certain locations. Seasonal analyses for specified additional pesticides are normally carried out at times corresponding to maximal agricultural use or run-off periods, i.e. in spring and fall seasons.

#### Drinking Water Guidelines

The Ministry of the Environment published a revised edition of "Ontario Drinking Water Objectives" in 1983.

The primary purpose of drinking water objectives is the protection of the health of the public consuming the water. Aesthetic considerations may also provide a basis for drinking water objectives, since the water should be pleasant to drink. The control of such aspects of water quality as hardness, corrosiveness, etc. is also important. The limits set are considered to outline the minimum requirements necessary to fulfill the above objectives, and may be either health-related or related to aesthetic and other considerations.

Because this survey covered such a large number of parameters, many of them did not have an ODWO. In order to be able to compare data results to health guidelines, it was necessary to refer to objectives and guidelines developed by other jurisdictions.

The footnotes to Table 1 indicate the sources and derivation of the various guidelines.

TABLE 1: DRINKING WATER SURVEILLANCE PROGRAM, PARAMETERS ANALYSED

| PARAMETER CATEGORY      | Objective Guideline (1) | Detection Limit | PARAMETER CATEGORY              | Objective Guideline (1) | Detection Limit |
|-------------------------|-------------------------|-----------------|---------------------------------|-------------------------|-----------------|
| <b>CHEMISTRY:</b>       |                         |                 | Barium                          | 1 mg/L                  | 0.001 mg/L      |
| Conductivity            | -                       | 0.01 UMHO/CM    | Boron                           | 5 mg/L                  | 0.02 mg/L       |
| Hardness                | -                       | 0.5 mg/L        | Beryllium                       | -                       | 0.001 mg/L      |
| Calcium                 | -                       | 0.1 mg/L        | Cyanide                         | 0.2 mg/L                | 0.001 mg/L      |
| Magnesium               | -                       | 0.05 mg/L       | Cadmium                         | 0.005 mg/L              | 0.0003 mg/L     |
| Sodium                  | -                       | 0.1 mg/L        | Cobalt                          | -                       | 0.001 mg/L      |
| Alkalinity              | -                       | 0.2 mg/L        | Chromium                        | 0.05 mg/L               | 0.001 mg/L      |
| pH                      | -                       | -               | Copper                          | 1 mg/L                  | 0.001 mg/L      |
| Fluoride                | 2.4 mg/L                | 0.01 mg/L       | Mercury                         | 1 µg/L                  | 0.01 µg/L       |
| Chloride                | 250 mg/L                | 0.2 mg/L        | Molybdenum                      | -                       | 0.001 mg/L      |
| Residue total (solids)  | -                       | 1 mg/L          | Nickel                          | -                       | 0.002 mg/L      |
| Turbidity               | 1 FTU                   | .01 FTU         | Lead                            | 0.05 mg/L               | 0.003 mg/L      |
| Phosphorus              | -                       | 0.002 mg/L      | Selenium                        | 0.01 mg/L               | 0.001 mg/L      |
| Phosphates              | -                       | 0.0005 mg/L     | Strontium                       | -                       | 0.001 mg/L      |
| Nitrogen Total Kjeldahl | 0.15 mg/L*              | 0.1 mg/L        | Vanadium                        | -                       | 0.001 mg/L      |
| Ammonium Total          | -                       | 0.05 mg/L       | Zinc                            | 5 mg/L                  | 0.001 mg/L      |
| Colour                  | 5 TCU                   | 0.5 TCU         |                                 |                         |                 |
| Nitrates Total          | 10 mg/L as N            | .05 mg/L        | <b>BACTERIOLOGY (RAW ONLY):</b> |                         |                 |
| Nitrite                 | 1 mg/L as N             | 0.0005 mg/L     | Total Coliform MF               | -                       | 0               |
|                         |                         |                 | Total Coliform MF BKGD          | -                       | 0               |
|                         |                         |                 | Fecal Coliform                  | -                       | 0               |
|                         |                         |                 | Standard Plate Count MF         | -                       | 0               |
| <b>METALS:</b>          |                         |                 |                                 |                         |                 |
| Uranium                 | 0.02 mg/L(t)            | 0.002 mg/L‡     | <b>(TREATED ONLY):</b>          |                         |                 |
| Iron                    | 0.3 mg/L                | 0.002 mg/L      | Present/Absent (P/A) Test       | Absent                  | Absent          |
| Manganese               | 0.05 mg/L               | 0.001 mg/L      | Total Coliform MF BKGD          | -                       | 0               |
| Aluminum                | -                       | 0.003 mg/L      | Fecal Coliform                  | 0                       | 0               |
| Arsenic                 | 0.05 mg/L               | 0.001 mg/L      | Standard Plate Count MF         | <500 orgs/mL            | 0               |

TABLE 1: DRINKING WATER SURVEILLANCE PROGRAM, PARAMETERS ANALYSED (cont'd)

| PARAMETER CATEGORY        | Objective Guideline (1) | Detection Limit | PARAMETER CATEGORY              | Objective Guideline (1)  | Detection Limit |
|---------------------------|-------------------------|-----------------|---------------------------------|--------------------------|-----------------|
| <b>VOLATILES:</b>         |                         |                 | <b>CHLOROAROMATICS:</b>         |                          |                 |
| 1,1-Dichloroethylene      | 0.3 µg/L(h)             | 1.0 µg/L        | Hexachloroethane                | 19000 ng/L(e)            | 1 ng/L          |
| Dichloromethane           | 40 µg/L(c)              | 5 µg/L          | 1,3,5-Trichlorobenzene          | 10000 ng/L(y)            | 5 ng/L          |
| TRS-1,2-Dichloroethylene  | -                       | 1 µg/L          | 1,2,4-Trichlorobenzene          | 15000 ng/L(y)            | 5 ng/L          |
| 1,1-Dichloroethane        | -                       | 1 µg/L          | Hexachlorobutadiene             | 4500 ng/L(e)             | 1 ng/L          |
| Chloroform                | 350 µg/L <sup>++</sup>  | 1 µg/L          | 1,2,3-Trichlorobenzene          | 10000 ng/L(y)            | 5 ng/L          |
| 1,1,1-Trichloroethane     | 1000 µg/L(c)            | 1 µg/L          | 2,4,5-Trichlorotoluene          | -                        | 5 ng/L          |
| 1,2-Dichloroethane        | 10 µg/L(h)              | 1 µg/L          | 2,3,6-Trichlorotoluene          | -                        | 5 ng/L          |
| Carbon Tetrachloride      | 3 µg/L(h)               | 1 µg/L          | 1,2,3,5-Tetrachloro-<br>benzene | -                        | 1 ng/L          |
| Benzene                   | 10 µg/L(h)              | 1 µg/L          | 1,2,4,5-Tetrachloro-<br>benzene | 38000 ng/L(e)            | 1 ng/L          |
| 1,2-Dichloropropane       | -                       | 1 µg/L          | 2,6,A-Trichlorotoluene          | -                        | 5 ng/L          |
| Trichloroethylene         | 30 µg/L(h)              | 1 µg/L          | 1,2,3,4-Tetrachloro-<br>benzene | -                        | 1 ng/L          |
| Dichlorobromomethane      | 350 µg/L <sup>++</sup>  | 1 µg/L          | Pentachlorobenzene              | 74000 ng/L(e)            | 1 ng/L          |
| Toluene                   | 100 µg/L(c)             | 1 µg/L          | Total PCB's                     | 3000 ng/L(t)             | 20 ng/L         |
| 1,1,2-Trichloroethane     | 6 µg/L(e)               | 1 µg/L          | <b>PESTICIDES:</b>              |                          |                 |
| Chlorodibromomethane      | 350 µg/L <sup>++</sup>  | 1 µg/L          | Hexachlorobenzene               | 10 ng/L(h)               | 1 ng/L          |
| Tetrachloroethylene       | 10 µg/L(h)              | 1 µg/L          | Heptachlor                      | 3000 ng/L <sup>+++</sup> | 1 ng/L          |
| Chlorobenzene             | 100-300 ng/L(h)*        | 1 ng/L          | Aldrin                          | 700 ng/L <sup>**</sup>   | 1 ng/L          |
| Trifluorochlorotoluene    | -                       | 1 µg/L          | PP-DDE                          | d                        | 1 ng/L          |
| Ethylbenzene              | 1400 µg/L(e)            | 1 µg/L          | Mirex                           | -                        | 5 ng/L          |
| Ethylene Dibromide        | 0.02 µg/L(x)            | 1 µg/L          | Alpha BHC                       | 700 ng/L(c)              | 1 ng/L          |
| P-Xylene                  | 620 µg/L(c)             | 1 µg/L          | Beta BHC                        | 300 ng/L(c)              | 1 ng/L          |
| M-Xylene                  | 620 µg/L(c)             | 1 µg/L          | Gamma BHC (Lindane)             | 4000 ng/L                | 1 ng/L          |
| O-Xylene                  | 620 µg/L(c)             | 1 µg/L          | Alpha Chlordane                 | 7000 ng/L <sup>***</sup> | 2 ng/L          |
| Total Trihalomethanes     | 350 µg/L <sup>++</sup>  | 3 µg/L          | Gamma Chlordane                 | 7000 ng/L <sup>***</sup> | 2 ng/L          |
| Bromoform                 | 350 µg/L <sup>++</sup>  | 1 µg/L          | Oxychlordane                    | -                        | 2 ng/L          |
| 1,1,2,2-Tetrachloroethane | 1.7 µg/L(e)             | 1 µg/L          |                                 |                          |                 |
| 1,4-Dichlorobenzene       | 400 µg/L(e)             | 1 µg/L          |                                 |                          |                 |
| 1,3-Dichlorobenzene       | 400 µg/L(e)             | 1 µg/L          |                                 |                          |                 |
| 1,2-Dichlorobenzene       | 400 µg/L(e)             | 1 µg/L          |                                 |                          |                 |

TABLE 1: DRINKING WATER SURVEILLANCE PROGRAM, PARAMETERS ANALYSED (cont'd)

| PARAMETER<br>CATEGORY | Objective<br>Guideline (1) | Detection<br>Limit | PARAMETER<br>CATEGORY | Objective<br>Guideline (1) | Detection<br>Limit |
|-----------------------|----------------------------|--------------------|-----------------------|----------------------------|--------------------|
| Pesticides (cont'd)   |                            |                    |                       |                            |                    |
| OP-DDT                | 30000 ng/L(d)              | 5 ng/L             |                       |                            |                    |
| PP-DDD                | d                          | 5 ng/L             |                       |                            |                    |
| PP-DDT                | d                          | 5 ng/L             |                       |                            |                    |
| Methoxychlor          | 100000 ng/L                | 5 ng/L             |                       |                            |                    |
| Heptachlor Epoxide    | 3000 ng/L+++               | 1 ng/L             |                       |                            |                    |
| Endosulfan 1          | 74000 ng/L(ea)             | 2 ng/L             |                       |                            |                    |
| Dieldrin              | 700 ng/L**                 | 2 ng/L             |                       |                            |                    |
| Endrin                | 200 ng/L                   | 4 ng/L             |                       |                            |                    |
| Endosulfan 2          | 74000 ng/L(ea)             | 4 ng/L             |                       |                            |                    |
| Endosulfan Sulphate   | -                          | 4 ng/L             |                       |                            |                    |
| Octachlorostyrene     | -                          | 1 ng/L             |                       |                            |                    |
| Toxaphene             | 5000 ng/L                  | PA(xx)             |                       |                            |                    |

Footnotes:

- (1) = Ontario Drinking Water Objectives (ODWO) for drinking water, unless noted.
- (t) = ODWO Interim maximum acceptable concentration (IMAC) for drinking water.
- (c) = California State Department of Health Action Level for drinking water.
- (d) = ODWO for DDT (contains other isomers such as OPDDT and PPDDT).
- (e) = US EPA ambient guideline; guideline levels when it is assumed that untreated water and fish and shellfish are consumed from the same body of water.
- (ea) = United States Environmental Protection Agency (US EPA) ambient level for endosulfan (contains other isomers).
- (h) = World Health Organization (WHO) guideline for drinking water.
- (h)\* = World Health Organization (WHO) Odour Threshold for drinking water.
- (x) = State of Florida, maximum contaminant level for drinking water.
- (xx) = the presence of toxaphene is detected in scan used; positive samples would be quantified by special additional analysis.
- (y) = New York State (Taste and Odour) proposed drinking water guideline.
- ++ = total Trihalomethanes.
- +++ = combined total; Heptachlor and Heptachlor Epoxide.
- \* = total Kjeldahl Nitrogen minus Ammonia Nitrogen.
- \*\* = total of Aldrin and Dieldrin.
- \*\*\* = Chlordane is a mixture of alpha and gamma isomers.
- ‡ = Analysis changed to mass spectrometry method in mid-1986, detection limit 0.0001 mg/L.



TABLE 1A: DRINKING WATER SURVEILLANCE PROGRAM SPECIAL PESTICIDES

|                           |                     |
|---------------------------|---------------------|
| Dicamba                   | Reldan              |
| 2,4-D                     | Ronnel              |
| 2,4-DB                    | Carbofuran          |
| 2,4-DP                    | Propoxur            |
| 2,4,5-T                   | IPC                 |
| Silvex (2,4,5-TP)         | Aminocarb           |
| Picloram                  | CIPC                |
| 2,4,6-Trichlorophenol     | Eptam               |
| 2,4,5-Trichlorophenol     | Benonyl             |
| 2,3,4-Trichlorophenol     | Bux                 |
| 2,3,5,6-Tetrachlorophenol | Diallate            |
| 2,3,4,5-Tetrachlorophenol | Sevin               |
| Pentachlorophenol         | Sutan               |
| Diazinon                  | Propazine           |
| Dichlorvos                | Atrazine            |
| Dursban                   | Simazine            |
| Ethion                    | Sencor (metribuzin) |
| Guthion                   | Bladex (Cyanazine)  |
| Malathion                 | Prometone           |
| Mevinphos                 | Ametryne            |
| Methyl Parathion          | Prometryne          |
| Methyl Trithion           | Atratone            |
| Parathion                 | Alachlor            |
| Phorate (Thimet)          | Metolachlor         |

## RESULTS AND DISCUSSION

The parameters analyzed fall into several categories: physical parameters and general chemistry (chemistry), bacterial parameters, metals, and organic substances including volatile and chloroaromatic substances and pesticides. Many of the substances analyzed for are naturally-occurring or treatment by-products.

The results of analysis of raw and treated water samples are shown in Tables 2 and 3. Table 2 shows the categories of parameters analyzed, as well as the total number of analyses which were completed in each category for both raw and treated water samples and the total number of positive results which were obtained. Table 3 lists the sampling dates and the numerical values for each parameter for which analysis produced a positive (quantifiable) result.

The Stoney Point Water Treatment Plant was sampled 10 times in 1986.

### (a) Non Organic Substances

There are 311 positive results of 360 reported analyses for physical parameters, such as pH and temperature and general chemistry tests. The results of these tests are used as an indication of the analytical validity and integrity of the samples, the general characteristics of the water, and as a guide to making an assessment of the treatment process; they may also indicate whether any changes occur during the time elapsing between sampling and actual analysis. Organic nitrogen exceeded the aesthetic ODWO in three treated water samples; levels of organic nitrogen above the limit can result in taste and odour problems.

Positive results were obtained for 29 analyses for bacterial parameters out of a total number reported of 73. These bacterial tests include those for species of paramount importance from a public health point of view, and those which assess the general bacteriological quality and characteristics of the water; by this means, a measure is obtained of the overall efficiency of water treatment processes. Two of the positive results obtained for treated water samples were for standard plate count (a measure of the total number of bacteria in a water sample) with the highest count being 3 organisms per mL; the ODWO recommend that treated water not exceed 500 organisms per mL for standard plate count.

Analyses of 401 tests for metals in the water samples were reported; of these 191 were positive results. Metals can occur naturally and most are generally regarded as being ubiquitous. However, some may be present in water as a result of industrial or other discharges. A small number of metals have public health significance.

Of those parameters discussed above for which there are ODWO, none exceeded the Objectives except for organic nitrogen. Nor did the levels exceed any guidelines for drinking water set by other jurisdictions, such as the U.S. Environmental Protection Agency (US EPA), the World Health Organization (WHO) and Health & Welfare, Canada (H&W, Canada). Furthermore, the results of these analyses are consistent with those obtained in other areas of the Great Lakes.

(b) Organic Substances

Of a total of 526 analyses for volatile organic compounds, only 36 were positive; these were from treated water samples and were all due to the presence of trihalomethanes.

Trihalomethanes (THMs) are acknowledged to be produced during the water treatment process and will almost always only occur in treated waters. Trihalomethanes are comprised mainly of chloroform, chlorodibromomethane and dichlorobromomethane with bromoform occurring occasionally. Results are reported for the individual compounds as well as for their sum, which is expressed as total trihalomethanes (total THM). The ODWO for total THM is 350 ug/L; this level was not exceeded in any of the water samples included in this report, the highest level recorded being 75 ug/L on March 18, 1986.

Four hundred and twenty eight (428) tests were carried out for twenty three different pesticides; none was found above trace levels. Nine special pesticides were analyzed for in both raw and treated water on two occasions (May 13, 1986 and December 15, 1986); this analysis is carried out only once or twice a year at each supply, on a seasonal basis, to correspond to the use and/or loss of such pesticides on agricultural land. The nine analyzed for were propazine, atrazine, simazine, Sencor, Bladex, prometone, ametryne, prometryne and atratone. Alachlor and metolachlor were two additional pesticides analyzed for on December 15, 1986. No special pesticides were found in raw or treated water samples. No analysis for chlorophenolic compounds was carried out.

Only three other organic compounds were found at quantifiable levels in treated water at this supply; these were all chloroaromatics, thus providing the 4 positive results out of a total of 244 analyses in this category. Hexachloroethane was found at 12 ng/L; while no ODWO exists for this compound, the US EPA has recommended an ambient water quality criteria (assuming both fish and untreated water are consumed from the same body of water over a lifetime) of 19000 ng/L.

1,2,3,5-tetrachlorobenzene was detected at 31 ng/L on June 18, 1986. There is no ODWO for this compound, nor is there any specific ambient water quality criteria. However, the 1,2,4,5-tetrachlorobenzene isomer, which is chemically similar, is considered to be the most toxic of the tetrachlorobenzene isomers. Thus, the 38000 ng/L US EPA ambient water quality criteria for 1,2,4,5-tetrachlorobenzene, can be applied to the 1,2,3,5-tetrachlorobenzene isomer with an extra margin of safety.

The chemical 2,3,6-trichlorotoluene was detected at 50 ng/L and 26 ng/L. It has been found in treated water at other supplies, as have other trichlorotoluene isomers (Drinking Water Survey, St. Clair-Detroit River Area\*). There is no drinking water guideline for this substance.

Review of these results, along with information from other DWSP sites\*, would indicate that certain chlorinated compounds, such as hexachloroethane,

---

\* Drinking Water Survey, St. Clair-Detroit River Area. Update August 1986. Ontario Ministry of the Environment.

and trichlorotoluenes appear more frequently in the treated water than in the raw water. The Ministry of the Environment (MOE) made a submission to the liaison group of the Canadian Council of Resource and Environment Ministries and the Federal/Provincial Advisory Committee on Environmental and Occupational Health (ACEOH) to consider setting drinking water guidelines for these compounds. The information will be forwarded to the ACEOH sub-committee on drinking water guidelines; MOE provides a representative for this sub-committee.

### CONCLUSIONS

The data reveal that for metals, inorganic ions, and bacterial parameters, raw water values are frequently in the detectable range; levels of metals and inorganics are also found in treated water. The levels of metals, inorganic compounds, and bacteria are consistent with those found in other water supplies in the province.

For the organic compounds, most are below detection levels, even though the most sophisticated equipment available was employed in the chemical analysis.

ODWO have not been established for some of the compounds analysed; for these few compounds, use was made of appropriate guidelines set by other agencies, such as the World Health Organization, the US Environmental Protection Agency, Health and Welfare Canada or other agencies. None of these guidelines was exceeded.

The report identifies some compounds detected for which drinking water guidelines are not yet available. These compounds have been submitted for consideration for setting drinking water guidelines to the appropriate expert groups by the Ministry of the Environment.

The treated water at the supply did not exceed any known health-related guidelines for organic substances applicable to drinking water.

TABLE 2  
STONEY POINT WATER TREATMENT PLANT

| PARAMETER GROUP |                    | TYPE OF SAMPLE |         |
|-----------------|--------------------|----------------|---------|
|                 |                    | RAW            | TREATED |
| 1.              | GENERAL CHEMISTRY  |                |         |
|                 | - Total samples    | 180            | 180     |
|                 | - Total positives  | 178            | 133     |
| 2.              | METALS             |                |         |
|                 | - Total samples    | 191            | 210     |
|                 | - Total positives  | 95             | 96      |
| 3.              | BACTERIOLOGY       |                |         |
|                 | - Total samples    | 34             | 39      |
|                 | - Total positives  | 25             | 4       |
| 4.              | VOLATILES          |                |         |
|                 | - Total samples    | 277            | 249     |
|                 | - Total positives  | 0              | 36      |
| 5.              | PESTICIDES         |                |         |
|                 | - Total samples    | 226            | 202     |
|                 | - Total positives  | 0              | 0       |
| 6.              | CHLOROAROMATICS    |                |         |
|                 | - Total samples    | 130            | 114     |
|                 | - Total positives  | 0              | 4       |
| 7.              | CHLOROPHENOLS      |                |         |
|                 | - Total samples    | Not analyzed   |         |
|                 | - Total positives  |                |         |
| 8.              | SPECIAL PESTICIDES |                |         |
|                 | - Total samples    | 20             | 20      |
|                 | - Total positives  | 0              | 0       |



Table 3

STONE POINT WATER TREATMENT PLANT DWSP RESULTS

02/17/87

| PARAMETERS   | UNITS      | SAMPLE DATE |          |          |          |          |          |          |          |          |          |  |
|--------------|------------|-------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|--|
|              |            | 86/01/06    | 86/01/15 | 86/01/29 | 86/02/26 | 86/03/18 | 86/04/07 | 86/04/21 | 86/05/13 | 86/06/18 | 86/12/15 |  |
| ALKALINITY   | MG/L-CAC R | 114.80      | 115.40   | 98.000   | 198.80   | 181.30   | 98.700   | 99.40    | 115.50   | 92.200   | 103.10   |  |
|              | T          | 95.400      | 58.800   | 84.000   | 174.40   | 162.10   | 79.200   | 68.200   | 72.600   | 71.000   | 78.100   |  |
| ALUMINUM     | MG/L-AL R  | .061        | .150     | .240     | .200     | .330     | .380     | .590     | .330     |          | .880     |  |
|              | T          | .180        | .065     | .086     | .170     | .220     | .047     | .034     | .320     | .051     | .069     |  |
| BARIUM       | MG/L-BA R  | .013        | .015     | .014     | .025     | .023     | .014     | .018     | .019     |          | .019     |  |
|              | T          | .016        | .015     | .012     | .020     | .018     | .013     | .014     | .015     | .017     | .014     |  |
| BORON        | MG/L-BO R  | .040        | .060     |          | .060     |          |          |          | .040     |          | .030     |  |
|              | T          | .040        | .050     | .030     | .040     | .040     |          |          | .030     | .020     | .020     |  |
| CALCIUM      | MG/L-CA R  | 42.000      | 43.500   | 35.800   | 81.000   | 75.000   | 35.300   | 34.400   | 40.000   | 31.600   | 37.700   |  |
|              | T          | 42.400      | 43.800   | 35.500   | 80.000   | 76.000   | 38.700   | 34.100   | 33.900   | 31.700   | 37.000   |  |
| CHLORIDE     | MG/L-CL R  | 13.600      | 14.000   | 13.200   | 39.600   | 49.800   | 12.400   | 11.600   | 14.550   | 9.500    | 12.500   |  |
|              | T          | 16.200      | 15.000   | 14.400   | 42.200   | 52.500   | 14.450   | 12.300   | 13.500   | 11.000   | 15.000   |  |
| COLOUR       | HZU R      | 15.500      | 14.000   | 15.500   | 20.500   | 14.500   | 13.000   | 6.500    | 5.000    | 7.500    | 11.000   |  |
|              | T          |             |          |          | 4.000    | 5.000    |          |          |          |          |          |  |
| CONDUCTIVITY | UMHO/CM R  | 322.00      | 324.00   | 293.00   | 606.00   | 588.00   | 277.00   | 265.00   | 315.00   | 249.00   | 288.00   |  |
|              | T          | 329.00      | 346.00   | 300.00   | 600.00   | 598.00   | 309.00   | 272.00   | 280.00   | 259.00   | 301.00   |  |
| COBALT       | MG/L-CO R  |             |          |          |          | .001     |          |          |          |          |          |  |
|              | T          |             |          |          |          |          |          |          |          |          |          |  |
| CHROMIUM     | MG/L-CR R  | .002        | .002     | .002     | .003     | .003     | .002     |          | .001     |          | .001     |  |
|              | T          | .002        | .002     | .002     | .003     | .003     | .002     |          |          |          |          |  |
| COPPER       | MG/L-CU R  | .006        | .007     | .009     | .011     | .025     | .015     | .015     | .014     |          | .002     |  |
|              | T          | .009        | .004     | .004     | .007     | .008     | .006     | .001     | .004     | .003     | .002     |  |

Table 3 (cont'd)

## STONE POINT WATER TREATMENT PLANT DWSP RESULTS

02/17/87

| PARAMETERS                          | UNITS      | SAMPLE DATE |          |          |          |          |          |          |          |          |          |
|-------------------------------------|------------|-------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
|                                     |            | 86/01/06    | 86/01/15 | 86/01/29 | 86/02/26 | 86/03/18 | 86/04/07 | 86/04/21 | 86/05/13 | 86/06/18 | 86/12/15 |
| FECAL COLIFORM MEMBRANE FILTRATION  | CT/100ML R |             |          |          |          |          |          |          |          | 14.000   | A3C      |
|                                     | T          |             |          |          |          |          |          |          |          |          |          |
| IRON                                | MG/L-FE R  | .006        | .130     | .210     | .160     | .280     | .360     | .630     | .320     |          | .830     |
|                                     | T          | .180        |          | .014     | .013     | .017     | .004     |          | .039     | .003     | .010     |
| FLUORIDE                            | MG/L-F R   | .130        | .120     | .100     | .170     | .180     | .110     | .100     | .130     | .120     | .120     |
|                                     | T          | .110        |          | .060     | .140     | .150     | .060     | .040     | .150     | .060     | .060     |
| FIELD COMBINED CHLORINE RESIDUAL    | MG/L-CL R  |             |          |          |          |          |          |          |          |          |          |
|                                     | T          | 1.400       |          | .100     |          | .200     | 1.200    | 1.430    | .300     | .200     | 1.620    |
| FIELD FREE CHLORINE RESIDUAL        | MG/L-CL R  |             |          |          |          |          |          |          |          |          |          |
|                                     | T          | 1.500       | 1.000    | .800     |          | .700     | 1.500    | 1.100    | 1.200    | .800     | 1.500    |
| FIELD TOTAL CHLORINE RESIDUAL       | MG/L-CL R  |             |          |          |          |          |          |          |          |          |          |
|                                     | T          | 1.900       |          | .900     | 1.000    | .900     | 2.300    | 1.500    | 1.500    | 1.000    | 1.720    |
| FIELD PH                            | R          | 7.400       | 7.800    | 7.800    | 7.800    | 7.800    | 7.800    | 7.800    | 7.800    | 7.600    | 7.600    |
|                                     | T          | 7.200       | 7.300    | 7.400    | 7.300    | 7.200    | 7.400    | 7.400    | 7.400    | 7.300    | 7.600    |
| FIELD TEMPERATURE                   | DEG.C R    | 3.000       | 4.000    | 2.000    | 3.500    | 3.000    | 8.500    | 9.000    | 15.000   | 19.000   | 2.000    |
|                                     | T          | 3.500       | 5.000    | 5.000    | 4.000    | 5.000    | 10.000   | 8.200    | 15.100   | 19.000   | 2.000    |
| FIELD TURBIDITY                     | FTU R      | 3.000       | 3.000    | 5.000    |          |          |          |          | 10.600   | 20.000   | 30.000   |
|                                     | T          | 1.000       | .100     | .200     |          |          |          | .300     | .260     | .150     | .350     |
| HARDNESS                            | MG/L-CAC R | 148.00      | 151.00   | 126.00   | 270.00   | 247.40   | 122.50   | 120.00   | 139.50   | 111.50   | 131.50   |
|                                     | T          | 148.00      | 152.00   | 126.00   | 265.00   | 250.70   | 133.00   | 119.00   | 118.50   | 111.50   | 128.00   |
| STANDARD PLATE COUNT MEMBRANE FILT. | CT/ML R    | 143.00      |          |          |          |          | 370.00   |          |          |          |          |
|                                     | T          |             |          |          |          |          | 3.000    | 1.000    |          |          |          |
| MERCURY                             | UG/L-HG R  | .050        | .010     |          | .010     |          |          |          |          |          | .030     |
|                                     | T          | .050        | .050     | .050     | .010     | .030     | .060     |          |          |          | .040     |

Table 3 (cont'd)

## STONEY POINT WATER TREATMENT PLANT DWSP RESULTS

02/17/87

| PARAMETERS              | UNITS     | SAMPLE DATE |          |          |          |          |          |          |          |          |          |
|-------------------------|-----------|-------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
|                         |           | 86/01/06    | 86/01/15 | 86/01/29 | 86/02/26 | 86/03/18 | 86/04/07 | 86/04/21 | 86/05/13 | 86/06/18 | 86/12/15 |
| MAGNESIUM               | MG/L-MG R | 10.300      | 10.300   | 9.000    | 16.450   | 14.600   | 8.300    | 8.350    | 9.550    | 7.900    | 9.100    |
|                         | T         | 10.250      | 10.350   | 9.150    | 15.800   | 14.800   | 8.850    | 8.250    | 8.250    | 7.800    | 8.750    |
| MANGANESE               | MG/L-MN R | .002        | .004     | .005     | .008     | .013     | .008     | .014     | .010     |          | .011     |
|                         | T         | .005        | .003     | .002     | .003     | .003     | .002     | .001     | .001     |          | .001     |
| MOLYBDENUM              | MG/L-MB R |             |          |          | .001     |          |          |          |          |          |          |
|                         | T         |             |          |          | .001     |          |          |          |          |          |          |
| SODIUM                  | MG/L-NA R | 7.500       | 7.000    | 7.500    | 21.300   | 25.500   | 6.600    | 7.200    | 9.000    | 6.000    | 7.200    |
|                         | T         | 7.500       | 7.500    | 7.500    | 21.300   | 25.500   | 6.900    | 6.700    | 7.200    | 6.000    | 7.000    |
| NICKEL                  | MG/L-NI R | .001        | .001     | .001     | .002     | .003     | .001     | .002     |          |          |          |
|                         | T         | .002        | .001     | .001     | .002     | .002     | .001     |          |          |          |          |
| AMMONIUM TOTAL          | MG/L-N R  | .018        |          | .016     | .082     | .096     | .012     | .024     | .020     | .024     | .024     |
|                         | T         | .008        | .008     | .008     |          | .008     |          | .008     | .020     | .020     |          |
| NITRITE                 | MG/L-N R  | .008        | .011     | .012     | .063     | .060     | .023     | .013     | .045     | .010     | .017     |
|                         | T         |             |          | .004     |          |          | .005     |          | .003     |          |          |
| TOTAL NITRATES          | MG/L-N R  | 1.410       | 1.540    | 1.100    | 4.390    | 4.310    | 1.190    | .705     | 1.100    | .655     | 1.120    |
|                         | T         | 1.370       | 1.550    | 1.100    | 4.350    | 4.410    | 1.400    | .575     | .610     | .575     | 1.100    |
| NITROGEN TOTAL KJELDAHL | MG/L-N R  | .290        | .270     | .270     | .600     | .670     | .370     | .500     | .330     | .260     |          |
|                         | T         | .160        | .070     | .150     | .390     | .390     | .130     |          | .090     | .070     |          |
| PH                      | R         | 8.080       | 8.090    | 8.160    | 7.690    | 8.050    | 8.260    | 8.200    | 8.280    | 8.270    | 8.330    |
|                         | T         | 7.220       | 6.580    | 7.600    | 7.350    | 7.770    | 7.370    | 7.620    | 7.380    | 7.660    | 8.020    |
| PHOSPHORUS FIL REACT    | MG/L-P R  | .007        | .005     | .005     | .040     | .042     | .015     | .008     | .006     | .011     | .006     |
|                         | T         |             |          | .003     |          |          |          |          |          |          |          |

Table 3 (cont'd)

## STONE POINT WATER TREATMENT PLANT DWSP RESULTS

02/17/87

| PARAMETERS                         | UNITS    | SAMPLE DATE    |            |            |          |            |            |            |            |            |            |
|------------------------------------|----------|----------------|------------|------------|----------|------------|------------|------------|------------|------------|------------|
|                                    |          | 86/01/06       | 86/01/15   | 86/01/29   | 86/02/26 | 86/03/18   | 86/04/07   | 86/04/21   | 86/05/13   | 86/06/18   | 86/12/15   |
| PHOSPHORUS TOTAL                   | MG/L-P   | R   .017       | .023       | .018       | .058     | .083       | .051       | .110       | .030       | .036       | .045       |
|                                    | T        |                | .007       |            |          | .013       |            |            |            |            |            |
| TOTAL SOLIDS                       | MG/L     | R   209.00 CRO | 211.00 CRO | 190.00 CRO | 402.00   | 385.00     | 183.00     | 264.00     | 205.00 CRO | 182.00     | 194.00     |
|                                    | T        | 214.00 CRO     | 225.00 CRO | 195.00 CRO | 403.00   | 389.00     | 201.00 CRO | 177.00 CRO | 182.00 CRO | 168.00 CRO | 179.00     |
| STRONTIUM                          | MG/L-SR  | R   .130       | .140       | .120       | .320     | .300       | .120       | .120       | .150       |            | .130       |
|                                    | T        | .140           | .130       | .120       | .310     | .290       | .130       | .100       | .120       | .120       | .130       |
| TOTAL COLIFORM MEMBRANE FILTRATION | CT/100ML | R   4.000 A3C  | 4.000 A3C  | 106.00 A3C | 500.00   | 142.00 A3C | 20.000 A3C | 15.000 A3C | 1.000      | 6.000 A3C  | 142.00 A3C |
|                                    | T        |                |            |            |          |            |            |            |            |            |            |
| TOTAL COLIFORM BACKGROUND MF       | CT/100ML | R   510.00     | 560.00     | 2900.0     | 1500.0   | 1000.0     | 1120.0     | 3000.0     | 280.00     | 5000.0     | 5000.0     |
|                                    | T        | 1.000          |            |            |          |            |            |            |            | 1.000      |            |
| TURBIDITY                          | FTU      | R   6.200      | 5.500      | 6.400      | 4.700    | 11.400     | 16.100     | 64.000     | 12.600     | 19.800     | 26.000     |
|                                    | T        |                |            |            |          |            |            |            |            |            | .300       |
| URANIUM                            | UG/L-U   | R              |            |            |          |            |            |            |            |            | .620       |
|                                    | T        |                |            |            |          |            |            |            |            |            |            |
| VANADIUM                           | MG/L-V   | R              |            |            | .003     | .001       |            | .001       | .001       |            | .002       |
|                                    | T        |                |            |            | .003     |            |            |            |            |            |            |
| CHLOROFORM                         | UG/L     | R              |            |            |          |            |            |            |            |            |            |
|                                    | T        |                | 14.000     | 39.000     | 49.000   | 54.000     | 24.000     | 12.000     | 48.000     | 38.000     | 24.000     |
| DICHLOROBROMOMETHANE               | UG/L     | R              |            |            |          |            |            |            |            |            |            |
|                                    | T        |                | 7.000      | 17.000     | 16.000   | 15.000     | 10.000     | 7.000      | 18.000     | 16.000     | 12.000     |
| CHLORODIBROMOMETHANE               | UG/L     | R              |            |            |          |            |            |            |            |            |            |
|                                    | T        |                | 12.000     | 13.000     | 8.000    | 6.000      | 6.000      | 7.000      | 5.000      | 7.000      | 3.000      |
| 1235 TETRACHLOROBENZENE            | NG/L     | R              |            |            |          |            |            |            |            |            |            |
|                                    | T        |                |            |            |          |            |            |            | 131.000    |            |            |

Table 3 (cont'd)

## STONEY POINT WATER TREATMENT PLANT DWSP RESULTS

02/17/87

| PARAMETERS            | UNITS   | SAMPLE DATE |          |          |          |          |          |          |          |          |          |  |
|-----------------------|---------|-------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|--|
|                       |         | 86/01/06    | 86/01/15 | 86/01/29 | 86/02/26 | 86/03/18 | 86/04/07 | 86/04/21 | 86/05/13 | 86/06/18 | 86/12/15 |  |
| HEXACHLOROETHANE      | NG/L    | R           |          |          |          |          |          |          |          |          |          |  |
|                       | T       |             |          |          |          |          |          |          | 12.000   |          |          |  |
| 236 TRICHLOROTOLUENE  | NG/L    | R           |          |          |          |          |          |          |          |          |          |  |
|                       | T       |             |          | 150.000  |          |          |          |          |          | 26.000   |          |  |
| TOTAL TRIHALOMETHANES | UG/L    | R           |          |          |          |          |          |          |          |          |          |  |
|                       | T       |             | 33.000   | 69.000   | 73.000   | 75.000   | 40.000   | 26.000   | 71.000   | 61.000   | 39.000   |  |
| ZINC                  | MG/L-ZN | R           | .004     | .006     | .008     | .008     | .009     | .006     | .009     | .006     | .005     |  |
|                       | T       | .005        | .010     | .005     | .005     | .005     | .007     | .005     | .031     | .005     | .004     |  |

TD  
380  
S76  
1987